

AN ORDINANCE OF THE MUNICIPALITY OF MONROEVILLE  
REQUIRING THE INSTALLATION OF PRODUCTS OF COM-  
BUSTION DETECTION FOR EXISTING ONE AND TWO FAMILY  
DWELLINGS

BE IT ORDAINED and ENACTED by the Municipality of Monroeville, in Council  
assembled as follows:

Section 1. That in every one and two family dwellings within thirty (30)  
days after title transfer or change of occupancy, that a product of com-  
bustion detection be installed.

Section 2. Such products of combustion detection shall contain the  
Underwriters Laboratory listing seal and be installed in accordance with  
National Fire Protection Standard Number 74.

ORDAINED and ENACTED this 14th day of February, 1978.

(SEAL)

ATTEST:

MUNICIPALITY OF MONROEVILLE

S/ Marshall W. Bond  
Municipal Manager

S/ Michael P. Lynch  
Mayor